

# METRIC INDICES FOR PERFORMANCE EVALUATION OF A MIXED MEASUREMENT BASED STATE ESTIMATOR

Paula Castro VIDE<sup>1</sup>, Fernando Pires Maciel BARBOSA<sup>2</sup>,  
Jose Antonio Beleza CARVALHO<sup>3</sup>

<sup>1</sup>Electrical Engineering Department, School of Technology and Management, Polytechnic Institute of Leiria, Campus 2 Morro do Lena - Alto do Vieiro, 2411-901 Leiria, Portugal

<sup>2</sup>INESC Technology and Science - Institute for Systems and Computer Engineering of Porto and Faculty of Engineering, University of Porto, FEUP campus Rua Dr. Roberto Frias, 4200 - 465 Porto, Portugal

<sup>3</sup>Superior Institute of Engineering of Porto, Polytechnic Institute of Porto, Rua Dr. Antonio Bernardino de Almeida, 431 4200-072 Porto, Portugal

paula.vide@ipleiria.pt, fmb@fe.up.pt, jbc@isep.ipp.pt

**Abstract.** *With the development of synchronized phasor measurement technology in recent years, it gains great interest the use of PMU measurements to improve state estimation performances due to their synchronized characteristics and high data transmission speed. The ability of the Phasor Measurement Units (PMU) to directly measure the system state is a key over SCADA measurement system. PMU measurements are superior to the conventional SCADA measurements in terms of resolution and accuracy. Since the majority of measurements in existing estimators are from conventional SCADA measurement system, it is hard to be fully replaced by PMUs in the near future so state estimators including both phasor and conventional SCADA measurements are being considered. In this paper, a mixed measurement (SCADA and PMU measurements) state estimator is proposed. Several useful measures for evaluating various aspects of the performance of the mixed measurement state estimator are proposed and explained. State Estimator validity, performance and characteristics of the results on IEEE 14 bus test system and IEEE 30 bus test system are presented.*

## Keywords

*Metrics, mixed measurements, performance evaluation, PMU measurement units, synchronized phasor measurements, state estimation, very large networks.*

## 1. Introduction

Phasor measurement units (PMU) are considered to be important devices used as measurement technology

on power systems, due to its unique ability to sample analogue voltage and current waveform data taken at distant points.

PMUs are equipped with Global Positioning System receivers allowing the synchronization of the several readings using the GPS-clock as it provides a precise timing pulse time-stamping power system information [1]. All information is sent to phasor data concentrators that compute the sinusoidal wave and the phasors representing the magnitude and phase angle of the voltage and current from widely dispersed locations in the system. As PMU technology is widely available and PMUs are beginning to be extensively deployed in electric power industry there is an increasing use of this measurement units in modern power systems for a wide range of applications. One well known application of the PMU bus phase angles is within the state estimator. State estimation is an important EMS application that provides real time, reliable and qualitative information on the system state. Many studies have been made on the subject [2], [3], [4], [5], [6], [7], [8], [9], [10], [11].

The worldwide deregulation process has significantly affected power system management and energy markets, as competitive markets will lead to more efficient power generation, more technological innovations and, eventually, to lower retail prices. In addition the power system network is growing larger and more complex as there are many independent power generators adding generation to the electric system and a continuous increase of load demand. In this situation, the function of state estimation is becoming more important, because it is the main tool for monitoring and control based on the real-time data received from the measurement system.

Due to their cost, the integration of these PMU devices will not be instantaneous and it is unlikely that they will replace SCADA system for state estimation and other EMS functions in a near future too. Based on this idea, this paper, under given the placement of PMU in the power system, presents a simple WLS mixed measurement (with SCADA and PMU measurements) based power system state estimation model and algorithm. Due to the simplicity of the relations between PMU measurements and the state variables, such approach opens the possibility of obtaining contribution to an effective improvement on state estimator performances. A key aspect in the evaluation of state estimation algorithms is the selection and proper interpretation of the metrics used for measuring and determining the performance and characteristics of the algorithm. As the estimator is predominantly data-dependent, that is of a statistical nature, its performance should be evaluated in a statistical sense, based on statistical measures. Various metrics have been adopted for assessing the effectiveness of state estimator in other technology areas.

To obtain the results stated, a MATLAB software package was developed and used in this work. The paper is divided into four sections. The first section presents an introduction to the subject and explains the motivation of the developed work. The second section deals with the mathematical formulation of the problem. The third section deals with issues related to the problem implementation. State estimator simulation results on IEEE 14 and IEEE 30 bus test system are also presented in the third section. The simulation results are examined and discussed exploring the statistical measures for evaluating various aspects of the performance of the implemented estimator. 14 IEEE bus test system and 30 IEEE bus test system are used as test systems. Conclusions are presented in the fourth section.

## 2. Mixed Measurement based State Estimator Formulation

### 2.1. WLS State Estimation Method

The power system state estimation is formulated based on the measurement equations that, for a given set of bus voltage, line flows and injection measurements,  $\vec{z}$ , related to the vectors of state variables,  $\vec{x}$ , and measurement noise  $\vec{e}$ , such as [12]:

$$\vec{z} = h(\vec{x}) + \vec{e}. \quad (1)$$

The function  $h(\vec{x})$  corresponds to the nonlinear function relating measurements to the system states. The

state vector  $\vec{x}$  is of dimension  $n$  and the measurement vector  $\vec{z}$  of dimension  $m$  where  $n < m$ .

The voltage magnitude and phase angle at all buses are chosen as state variables, defined by a vector  $\vec{x}$ .

The achievement of an estimate for the system state variables vector using the weighted least square method (WLS) consists in determining the state vector  $\vec{x}$  that minimizes the following function:

$$J(\vec{x}) = [\vec{z} - h(\vec{x})]^T \mathbf{R}^{-1} [\vec{z} - h(\vec{x})]. \quad (2)$$

This estimate should satisfy at least the first order optimality constraints as:

$$g(\vec{x}) = \frac{\partial J(\vec{x})}{\partial \vec{x}} = -\mathbf{H}^T(\vec{x}) \mathbf{R}^{-1} [\vec{z} - h(\vec{x})] = 0, \quad (3)$$

where  $\mathbf{H}(\vec{x})$  is the jacobian matrix of  $h(\vec{x})$  for  $\vec{x}$ , i.e:

$$\mathbf{H}(\vec{x}) = \left[ \frac{\partial h(\vec{x})}{\partial \vec{x}} \right]. \quad (4)$$

Due to the non-linearity of the function  $h(\vec{x})$ , expanding the nonlinear function  $g(\vec{x})$  into its Taylor series expansions we have:

$$g(\vec{x}) = g(\vec{x}^k) + \mathbf{G}(\vec{x}^k)(\vec{x} - \vec{x}^k) + \dots = 0. \quad (5)$$

The first-order Taylor series expansions of (1) yield:

$$\vec{x}^{k+1} = \vec{x}^k - [\mathbf{G}(\vec{x}^k)]^{-1} g(\vec{x}^k), \quad (6)$$

where  $\vec{x}^0$  is initial estimate for the start of an iterative process,  $k$  is iterations counter and  $\vec{x}^k$  is solution vector obtained at  $k$ -th iteration.

PMUs have the ability to measure the voltage magnitude on buses and also the currents in adjacent lines. The incorporation of these phasor measurements will extend the measurement vector as it contains voltage phase angle and current phasor measurements, besides conventional SCADA measurements (voltage magnitude, active/reactive power injections and power flow measurement). The approach followed considers the injected current at the buses that have a PMU placed. The use of the PMU data further complicates the approach because it creates conflicts between quantities expressed in rectangular coordinates and polar coordinates. System state is expressed in polar coordinates, thus the injected currents are expressed as nonlinear functions of magnitude and phase angle voltages at buses. Evidently, phase angle and magnitude of injected currents can be calculated from the rectangular components, but the problem lies in the characterization of the covariance of measurement errors, [13].

Adding phasor measurements, due to the use of PMU, to an existing system which already contains  $m$  measurements causes the jacobian matrix to augment

$$\frac{\partial I_{iREAL}}{\partial \delta} \rightarrow \begin{cases} \frac{\partial I_{iREAL}}{\partial \delta_i} = -V_i (\mathbf{G}_{ii} \sin \delta_i + \mathbf{B}_{ii} \cos \delta_i) \\ \frac{\partial I_{iREAL}}{\partial \delta_j} = -V_j (\mathbf{G}_{ij} \sin \delta_j + \mathbf{B}_{ii} \cos \delta_j) \end{cases} \quad (7)$$

$$\frac{\partial I_{iREAL}}{\partial V} \rightarrow \begin{cases} \frac{\partial I_{iREAL}}{\partial V_i} = (\mathbf{G}_{ii} \cos \delta_i - \mathbf{B}_{ii} \sin \delta_i) \\ \frac{\partial I_{iREAL}}{\partial V_j} = (\mathbf{G}_{ij} \cos \delta_j - \mathbf{B}_{ii} \sin \delta_j) \end{cases} \quad (8)$$

$$\frac{\partial I_{iMAG}}{\partial \delta} \rightarrow \begin{cases} \frac{\partial I_{iMAG}}{\partial \delta_i} = V_i (\mathbf{G}_{ii} \cos \delta_i - \mathbf{B}_{ii} \sin \delta_i) \\ \frac{\partial I_{iMAG}}{\partial \delta_j} = V_j (\mathbf{G}_{ij} \cos \delta_j - \mathbf{B}_{ii} \sin \delta_j) \end{cases} \quad (9)$$

$$\frac{\partial I_{iMAG}}{\partial V} \rightarrow \begin{cases} \frac{\partial I_{iMAG}}{\partial V_i} = \mathbf{G}_{ii} \sin \delta_i + \mathbf{B}_{ii} \cos \delta_i \\ \frac{\partial I_{iMAG}}{\partial V_j} = \mathbf{G}_{ij} \sin \delta_j + \mathbf{B}_{ii} \cos \delta_j \end{cases} \quad (10)$$

with added rows corresponding to the partial derivatives of real and imaginary parts of the injected current in order to voltage magnitude and its phase angle (7), (8), (9), (10). The susceptance of the branches were considered as  $b_{0i} \gg g_{0i}$ .

The measurements received from PMUs are more accurate when compared to conventional SCADA measurements. Therefore, including PMU measurements in state estimator is expected to produce more accurate estimates. The structure of the modified measurement jacobian matrix will be as follows:

$$\mathbf{H}(\vec{x}) = \begin{bmatrix} \frac{\partial P_{ij}}{\partial \delta} & \frac{\partial P_{ij}}{\partial V} \\ \frac{\partial P_i}{\partial \delta} & \frac{\partial P_i}{\partial V} \\ \frac{\partial Q_{ij}}{\partial \delta} & \frac{\partial Q_{ij}}{\partial V} \\ \frac{\partial Q_i}{\partial \delta} & \frac{\partial Q_i}{\partial V} \\ \frac{\partial V_i}{\partial \delta} & \frac{\partial V_i}{\partial V} \\ \frac{\partial \delta_i}{\partial \delta} & \frac{\partial \delta_i}{\partial V} \\ \frac{\partial V_i}{\partial \delta} & \frac{\partial V_i}{\partial V} \\ \frac{\partial I_{ireal}}{\partial \delta} & \frac{\partial I_{ireal}}{\partial V} \\ \frac{\partial I_{imag}}{\partial \delta} & \frac{\partial I_{imag}}{\partial V} \end{bmatrix} \quad (11)$$

The gain matrix is formed using the measurement jacobian matrix and the measurement error covariance matrix  $\mathbf{R}$ . This covariance matrix is assumed to be the diagonal measurement variances entries. The variances of the measurements are typically given in terms of variance or standard deviation on the magnitude and angle. The approach followed requires covariance matrix elements in corresponding to phasor rectangular components. Thus, it is necessary to transform them. Since voltage phasor measurements are direct measures, its error covariance matrix can be calculated based on the error distribution. According to [14],

the standard deviations of the errors of voltage phasor measurement can be set as 0,0017 rad (phase angle) and 0,002 p.u. (magnitude), and thus their squares are the corresponding diagonal elements of error covariance matrix. The error covariance matrix for phasor currents measurements are calculated as covariance matrix of indirect measurements according to the known error variances of the direct measurements. The variance assigned to each measurement provides an indication of the certainty about that particular measurement.

The variance errors due to the measurement transformation can be calculated by:

$$\sigma_{I_{ireal}}^2 = \left( \frac{\partial I_{ireal}}{\partial |I_i|} \right)^2 \sigma_{|I_i|}^2 + \left( \frac{\partial I_{ireal}}{\partial \theta_{I_i}} \right)^2 \sigma_{\theta_{I_i}}^2, \quad (12)$$

$$\sigma_{I_{imag}}^2 = \left( \frac{\partial I_{imag}}{\partial |I_i|} \right)^2 \sigma_{|I_i|}^2 + \left( \frac{\partial I_{imag}}{\partial \theta_{I_i}} \right)^2 \sigma_{\theta_{I_i}}^2, \quad (13)$$

where  $\sigma_{I_{ireal}}^2$  and  $\sigma_{I_{imag}}^2$  are the error variances of  $I_{ireal}$  and  $I_{imag}$  respectively. Thus, with  $\sigma_{\theta_{I_i}}$  and  $\sigma_{|I_i|}$  the corresponding diagonal elements of error covariance matrix  $(\sigma_{I_{ireal}}^2, \sigma_{I_{imag}}^2)$  can be calculated.

## 2.2. Observability Analysis

Observability problem consists on identifying a set of available measurements enough to be able to estimate system state. For observability purposes not only is important the number of measurements but also their types and locations. If the system state is observable, it is relevant to identify measurements that, if missing, render the state unobservable. In this paper, an algorithm based on observability analysis method introduced earlier in [12] is used for observability analysis. It simultaneously allows checking observability, determining all observable islands and irrelevant boundary injections, and identifying pseudo-measurements



### 2.3. Measures of Accuracy

The performance of the estimator determines the estimator capability to provide the outputs in due time to be use by other applications in the control center.

The value of the indirectly  $J_x$  expresses how good the solution of the state estimation is, i.e., the fit between the measurements and linking of system states. This widely accepted index does not fully serve the purposes as this index shows how properly the solution fits to the measurements but it does not reflect how distant the estimate is from the real values. Contrary to that, in this paper it is discussed several indexes that quantify the performance of the state estimator with respect to the deviation of the state vector from the real conditions. Also the convergence capability of the estimator is analyzed resorting to the use of specific indicators.

The metric  $Mconv_{obj}$  evaluates the relative change in the value of the objective function at the  $k$ -th iteration, evaluating its ability to converge [16]. Such metric is defined as:

$$Mconv_{obj} = \left| 1 - \frac{J^k}{J^{k-1}} \right|, \quad (19)$$

$$Mconv_v = \max \left| 1 - \frac{V_i^k}{V_i^{k-1}} \right|. \quad (20)$$

The metric  $Mconv_\theta$  measures the largest final relative change in bus voltage phase angle; it uses the absolute difference to avoid problems when the angle is near zero, which will occur near the system reference bus, [16]:

$$Mconv_\theta = \max |\theta_i^k - \theta_i^{k-1}|. \quad (21)$$

Other metrics are used to indicate the deviation of estimated state variables from real values. With this purpose it can be used a norm metric  $Macc_v$  that captures the effect of both voltage magnitude errors and voltage angle errors, as:

$$Macc_v = \sqrt{\sum_i |\vec{V}_i^{real} - \vec{V}_i^{estimated}|^2}. \quad (22)$$

To evaluate solution accuracy related to voltage magnitude it is used the metric MAPE, which expresses voltage magnitude mean absolute percentage error:

$$MAPE = \frac{100\%}{m} \sum_{i=1}^m \frac{|\vec{V}_i^{real} - \vec{V}_i^{estimated}|}{\vec{V}_i^{real}}. \quad (23)$$

In terms of voltage phase angle, estimated values are evaluated using the metrics  $MAE_\theta$ , which expresses voltage phase angle mean absolute error, measuring how close estimated voltage phase angles are to the actual values in the system.

$$MAE_\theta = \frac{1}{m} \sum_{i=1}^m |\theta_i^{real} - \theta_i^{estimated}|. \quad (24)$$

The simulation procedure followed, the test system used and the results of the state estimator simulation analyzed by the metrics referred are presented in the next section.

## 3. Simulation Considerations and Results

The proposed method for mixed measurements based state estimator is implemented in Matlab and tested on the IEEE 14 bus and IEEE 30 bus test systems [17].

### 3.1. Simulation Considerations

A set of SCADA measurements mostly power flows and power injections are arbitrarily distributed in the system. A load flow is carried out using the load and generation values and its outcome serves as the true state and true value of measurements that include bus voltage magnitude, bus power injections and power flows. The actual measurements  $z$  are obtained by adding true value of measurements with normally distributed noise of 1 % standard deviation for power injections, 0,8 % for power flows and 8 % for voltage measurements. All measurements have the exactly same error characteristics.

For buses that don't have any load or generation, the injection at those buses into the rest of the system is known to be exactly zero. As in these zero injection buses the injection is zero, it can be interpreted the zero injection as an exact measurement of the real and reactive power. One possibility to deal with these implicit measurements on state estimation problem is to ignore the zero injection buses in the formulation. The drawback of this consideration is that if there are many zero injections buses and if they are all ignored, then the remaining system is likely to be unobservable because the remaining measurements will be insufficient to completely determine the variables unknowns.

In order to identify the observable islands in the system a numerical observability analysis as described at Section 2.2 is carried out. The PMUs are placed according to the placement methodology described, so that the total number of PMUs is minimized, and the measurement redundancy at the buses maximized. Voltage phasor measurement errors standard deviations are set to 0,0017 rad for phase angle and 0,002 p.u. for magnitude.

Taking into account the statistical nature of the measurements errors used in the simulation, a large number of trials is performed. For each trial, the sample of a measurement is randomly taken from the normal distribution of the measurement around the measured

value. So on each trial state estimator has the same measurement set but new errors are added to the measurements. It was simulated 150 trials. Thus it is possible to discard the statistical nature of measurements error on estimator outcomes. To make it easier to understand and interpret the large set of data from the 150 state estimation trials it was used box plots. It is a very useful tool for graphically portraying the distribution of state estimator results.

The voltage phase angles obtained by state estimator are all with respect to a reference bus. In SCADA measurement system, usually one bus (slack bus for most cases) is chosen as the reference bus to get the relative phase angles of all other buses in the system. Synchronized phasor measurements might have a different reference which is determined by the instant synchronized sampling initiated. If phase angle measurements are added, without considering the different references, the algorithm is not likely to converge. State estimation results will be incorrect if the PMU measurements are used without dealing with the reference problem. The solution followed, was to measure the phase angle of the slack bus (considered the reference in SCADA system) by placing a PMU at that bus and consider it as a common reference. State estimator algorithm convergence tolerance considered was  $10^{-5}$ .

### 3.2. IEEE 14 Bus Test System Simulation Results

The IEEE 14 bus test system measurement set with SCADA measurements is illustrated in Fig. 1.




Fig. 1: IEEE 14 bus test system measurement configuration.

There is only one zero injection bus, bus 7, which was taken into consideration in setting initial SCADA measurements allocation. Power flows in all adjacent branches to bus 7 are part of the initial measurement

set. After observability procedure completed all IEEE 14 bus test system observable regions are identified, as they are separated by the unobservable branches (see Fig. 1). It was verified that PMU'S were needed to satisfy system observability.

To deal with the reference problem it is required to place a PMU at bus 1, as bus 1 is the slack bus and so it will be considered as a common reference. It was used measures from available PMUs located at the buses 6, 5, 9, 10 and 14. The following locations for PMU were simulated to verify the effectiveness of the performance indexes in state estimator evaluation, creating 8 scenarios:

- PMUs at buses 1, 6, 9,
- PMUs at buses 1, 6, 14,
- PMUs at buses 1, 6, 10,
- PMUs at buses 1, 5, 9,
- PMUs at buses 1, 5, 14,
- PMUs at buses 1, 5, 10,
- PMUs at buses 1, 6,
- PMUs at buses 1, 9.

Figure 2 illustrates the convergence behavior of the state estimator when applied to the IEEE 14 bus test system. It describes the relative change in the value of function  $J_x$  at the last two iterations for all scenarios, evaluating state estimator ability to converge. Throughout careful analysis of Fig. 2, it can be seen how data from 150 state estimator trials related to the index  $Mconv_{obj}$  are distributed relative to the position of the measure of central tendency.




Fig. 2: Relative change of  $J_x$  at the last iteration.

For the scenario *PMUs at buses 1, 6, 9* and *PMUs at buses 1, 6*  $Mconv_{obj}$  data are spread more to the lower part of the center. Also it can be seen that scenario *PMUs at buses 1, 5, 10*, and scenario *PMUs at buses*

1, 9  $Mconv_{obj}$  data are clustered closer to the median. Scenario  $PMUs$  at buses 1, 6, 14 presents the lower relative change of function  $J_x$  at the last two iterations but also it expresses the more spread out relative to the mean values of relative change of function  $J_x$  of the 150 trials. It is possible to identify outliers on  $Mconv_{obj}$  for scenario  $PMUs$  at buses 1, 5, 10 and scenario  $PMUs$  at buses 1, 9.

Figure 3 and Fig. 4 describe the largest final relative change in bus voltage magnitude and phase angle. It is possible to preview state estimator performance in terms of convergence for each scenario.




Fig. 3: Largest final relative change on bus voltage magnitude.

Figure 3 and Fig. 4 shows a similar behavior on all scenarios results related to both the largest final relative change on bus voltage magnitude and on bus phase angle. Scenario  $PMUs$  at buses 1, 6, 9 and  $PMUs$  at buses 1, 6 present  $Mconv_v$  data spread more to the upper part of the center. The more clustered closer to the median data is a better choice. It seems to be because the index does not vary as much from simulation trial to simulation trial.




Fig. 4: Largest final relative change on bus phase angle.

Outliers are not present in every scenario. When they are present they are outside of the boundaries of the whiskers. These outliers are extreme values that deviate significantly from the rest of results. This is

consistent with the results on measures of the largest final relative change in bus voltage magnitude and in bus voltage phase angle showed by Fig. 3 and Fig. 4 for scenarios  $PMUs$  at buses 1, 6, 14,  $PMUs$  at buses 1, 5, 9,  $PMUs$  at buses 1, 5, 14,  $PMUs$  at buses 1, 5, 10 and  $PMUs$  at buses 1, 6, 9,  $PMUs$  at buses 1, 6, 10,  $PMUs$  at buses 1, 9, respectively.

The state estimator performance in terms of accuracy for all simulations is graphically presented by metrics  $MAPE$ ,  $MAE_\theta$  and  $Macc_v$  in Fig. 5, Fig. 6 and Fig. 7 respectively.

The mean absolute percentage error ( $MAPE$ ) is useful because it expresses, in generic percentage terms, the voltage magnitude error. It is easily demonstrated the estimator results accuracy with respect to voltage magnitude estimates. Figure 5 shows the  $MAPE$  for voltage magnitude errors for all simulations scenarios. It can be seen that for almost every simulation scenario  $MAPE$  is less than 0,35 %, indicating a very good estimator accuracy on voltage magnitude estimated values. The worst case scenario is for measurement set with  $PMUs$  at buses 1, 6.




Fig. 5: Mean absolute voltage magnitude percentage error.

Problems can occur when calculating the  $MAPE$  value with a series of small denominators such as voltage phase angle at reference bus. Thus a singularity problem of the form 'one divided by zero' caused by a small deviation in error occurs in this case. Due to that, the metric use to analyze phase angle error was Mean Average voltage phase angle Error ( $MAE_\theta$ ). Figure 6 shows voltage phase angle errors for all scenarios trials simulations. The metric used,  $MAE_\theta$ , indicates the average of the absolute values of the differences between estimated voltage phase angle and the corresponding real voltage phase angle.

Results indicate that the worst case in terms of voltage phase angle estimates is the simulation with measurement set with  $PMUs$  at buses 1,6 and  $PMUs$  at buses 1, 9. Note that the remaining voltage phase angle errors are lower than  $2e^{-3}$  rad (approximately 0,1 deg).




Fig. 6: Mean Absolute Phase Angle Error ( $MAE_{\theta}$ ).

It is reasonable to compare voltage magnitude errors and voltage phase angle errors separately.  $Macc_v$  combines both capturing the effect of both, so state estimator should return low values on that metrics.




Fig. 7:  $Macc_v$  combines voltage magnitude and voltage phase angle error capturing the effect of both.

Figure 7 shows that  $Macc_v$  is lower than 0,015 for all simulations scenarios. The median data values of  $Macc_v$  are around 0,01 and the simulations with *PMU at bus 1, 6, 10* and *PMU at bus 1, 5, 9*, are the ones that present  $Macc_v$  values from the 150 trials more clustered closer to the median value, which indicates that the state estimator for these simulation scenarios has a greater ability to match the controlled test model in the aggregate.

### 3.3. IEEE 30 Bus Test System Simulation Results

The state estimator algorithm is also applied on the IEEE 30 bus test system. Figure 8 shows the bus test system measurement configuration used.

Observability analysis was carried out as described in section 2.2. Once identified the network observable regions, measurements are added to the measurement set in order to join these observable regions and establish




Fig. 8: IEEE 30 bus test system measurement configuration.

a single observable region. These measurements correspond to flows in the identified unobservable branches and bus injections at buses that are on the border of the observable islands. Figure 8 illustrates the observable islands identified. The measurements used to establish a single observable system were from available PMUs located at the selected buses, creating 3 simulation scenarios:

- PMUs at buses 1, 2, 6, 10, 12, 15, 16, 28.
- PMUs at buses 1, 2, 6, 12, 16, 24, 27.
- PMUs at buses 1, 2, 5, 10, 12, 25, 28.

A PMU is placed at bus 1 to measure the phase at system slack bus. The other PMU location where chosen to maximize the coverage allowing the use of a minimal PMU set. 150 simulations trials were carried out for the three scenarios. The simulation considerations assumed for IEEE 14 bus test system are the same for IEEE 30 bus test system. Simulation results are analyzed through the use of state estimation performance evaluation metrics when using phasor measurements on state estimator measurement set.

Metrics analysis is presented for IEEE 30 bus test system state estimation solution. Visual comparison is enhanced when using box plots to show metrics distribution calculated from state estimator outputs for each of 150 simulation trials.

Figure 9, Fig. 10 and Fig. 11 show convergence comparison for all three simulation scenarios. It can be said that the relative change of  $J_x$  at the last iteration is lower for scenario *PMUs at buses 1, 2, 6, 10, 12, 15, 16, 28*. Scenario *PMUs at buses 1, 2, 5, 10, 12, 25, 28*, exhibits data related with largest final relative






Fig. 9: Relative change of  $J_x$  at the last iteration.




Fig. 12:  $Macc_v$  combines voltage magnitude and voltage phase angle error capturing the effect of both.




Fig. 10: Largest final relative change on bus voltage magnitude.




Fig. 13: Mean absolute voltage magnitude percentage error.




Fig. 11: Largest final relative change on bus phase angle.




Fig. 14: Mean absolute phase angle error ( $MAE_\theta$ ).

change on bus voltage magnitude clustered closer to the median. Also scenario *PMUs at buses 1, 2, 5, 10, 12, 25, 28* presents the lower values for the largest final relative change on bus phase angle.

From plots presented on Fig. 13 and Fig. 14, scenario *PMU at buses 1, 2, 5, 10, 12, 25, 28* has the better state estimator performance in terms of voltage magnitude and voltage phase angle error. For this scenario metrics  $MAPE$  and  $MAE_\theta$  have the lower median value and the outcomes of the 150 simulation trials are more clustered closer to the median value when comparing with the other scenarios.  $Macc_v$  metric box plot also indicates that a very high number of simulation trials results are contained within a very small segment of the sample for scenario *PMU at buses 1, 2, 5, 10, 12, 25, 28*. Also this scenario presents the higher relative change of function  $J_x$  at the last two iterations, meaning that state estimation presents better performance in terms of convergence for the scenario *PMUs at buses 1, 2, 6, 10, 12, 15, 16, 28*.

## 4. Conclusion

This paper presents a methodology for a mixed measurements based state estimator. Several practical metrics for evaluating state estimator performance were discussed. They are useful for measuring different aspects of the estimator performance. The algorithm implemented was tested in IEEE 14 bus test system and for IEEE 30 bus test system with different number of PMU measurements and constant SCADA measurement set. Estimator performance evaluation was carried out for the several measurements sets for comparison purpose. Simple metrics cannot capture a complete picture of the estimator but those that are more complete are also more complex and subject to subjective interpretations. The state estimation performance evaluation through the metrics shows that the implemented algorithm for mixed measurements based state estimator can be applied with good results.

## Acknowledgment

The first author gratefully acknowledges the financial support of the Portuguese Foundation for Science and Technology (FCT) under Project No SFRH/BD/43208/2008.

## References

- [1] NUQUI, R. F. *State Estimation and Voltage Security Monitoring Using Synchronized Phasor Measurements*. Blacksburg, 2001. Doctoral work. VirginiaTech.
- [2] MING, Z., V. A. CENTENO, J. S. THORP and A. G. PHADKE. An Alternative for Including Phasor Measurements in State Estimators. *IEEE Transactions on Power Systems*. 2006, vol. 21, iss. 4, pp. 1930–1937. ISSN 0885-8950. DOI: 10.1109/TPWRS.2006.881112.
- [3] ABUR, A. Impact of phasor measurements on state estimation. In: *International Conference on Electrical and Electronics Engineering, 2009. ELECO 2009*. Bursa: IEEE, 2009, pp. 1-3-1-7. ISBN 978-1-4244-5106-7.
- [4] CHAKRABARTI, S., E. KYRIAKIDES, G. VALVERDE and V. TERZIJA. State estimation including synchronized measurements. In: *IEEE Bucharest PowerTech, 2009*. Bucharest: IEEE, 2009, pp. 1–5. ISBN 978-1-4244-2234-0. DOI: 10.1109/PTC.2009.5282018.
- [5] RICE, M. J. and G. T. HEYDT. Power Systems State Estimation Accuracy Enhancement Through the Use of PMU Measurements. In: *IEEE PES Transmission and Distribution Conference and Exhibition, 2005/2006*. Dallas: IEEE, 2006, pp. 161-165. ISBN 0-7803-9194-2. DOI: 10.1109/TDC.2006.1668476.
- [6] BALTENSBERGER, R., A. LOOSLI, H. SAUVAIN, M. ZIMA, G. ANDERSSON and R. NUQUI. An implementation of two-stage hybrid state estimation with limited number of PMU. In: *Managing the Change, 10th IET International Conference on Developments in Power System Protection (DPSP 2010)*. Manchester: IEEE, 2010, pp. 1–5. DOI: 10.1049/cp.2010.0261.
- [7] JUNJIE, T., M. LIXIA, L. JUNQI, C. MUSCAS, and A. MONTI. Impact of PMU synchronization on wide area state estimation. In: *IEEE International Workshop on Applied Measurements for Power Systems (AMPS), 2011*. Aachen: IEEE, 2011, pp. 74–79. ISBN 978-1-61284-946-1. DOI: 10.1109/AMPS.2011.6090430.
- [8] LIUXI, Z. and A. ABURA. State estimator tuning for PMU measurements. In: *North American Power Symposium (NAPS), 2011*. Boston: IEEE, 2011, pp. 1–4. ISBN 978-1-4577-0417-8. DOI: 10.1109/NAPS.2011.6025196.
- [9] HERNANDEZ, B. V. and J. M. RAMIREZ. Assessing a state estimator under a set of hybrid measurements. In: *North American Power Symposium (NAPS), 2010*. Arlington: IEEE, 2010, pp. 1–7. ISBN 978-1-4244-8046-3. DOI: 10.1109/NAPS.2010.5619953.
- [10] VALVERDE, G., S. CHAKRABARTI, E. KYRIAKIDES, and V. TERZIJA. A Constrained Formulation for Hybrid State Estimation. *IEEE Transactions on Power Systems*. 2010, vol. 26, iss. 3, pp. 1102–1109. ISSN 0885-8950. DOI: 10.1109/TPWRS.2010.2079960.
- [11] VANFRETTI, L., J. H. CHOW, S. SARAWGI, and B. FARDANESH. A Phasor-Data-Based State Estimator Incorporating Phase Bias Correction. *IEEE Transactions on Power Systems*. 2011, vol. 26, iss. 1, pp. 111–119. ISSN 0885-8950. DOI: 10.1109/TPWRS.2010.2047031.
- [12] ABUR, A. and A. G. EXPOSITO. *Power System State Estimation: Theory and Implementation*. New York: CRC Press, 2004. ISBN 978-0824755706.
- [13] BI, T. S., X. H. QIN and Q. X. YANG. A novel hybrid state estimator for including synchronized phasor measurements. *Electric Power Systems Research*. 2008, vol. 78, iss. 8, pp. 1343–1352. ISSN 0378-7796. DOI: 10.1016/j.epsr.2007.12.002.
- [14] C37.118.1-2011. *IEEE Standard for Synchrophasor Measurements for Power Systems*. New York: IEEE, 2011.
- [15] VIDE, P. S. Castro, F. P. Maciel BARBOSA and I. M. FERREIRA. Use of available phasor measurements for system observability: A case study. In: *International Conference on Power Engineering, Energy and Electrical Drives, 2009. POWERENG '09*. Lisbon: IEEE, 2009, pp. 95–100. ISBN 978-1-4244-4611-7. DOI: 10.1109/POWERENG.2009.4915251.
- [16] Power Systems Test Case Archive. *University of Washington: Electrical Engineering* [online]. 1999. Available at: <http://www.ee.washington.edu/research/pstca>.
- [17] Metrics for Determining the Impact of Phasor Measurements on Power System State Estimation. In: *Eastern Interconnection Phasor Project* [online]. 2006. Available at: <http://certs.lbl.gov/certs-eipp.html>.

## About Authors

**Paula Castro VIDE** was born in Funchal (Portugal). In 1997 she graduated in Electrical Engineering in the Faculty of Sciences and Technology of the University of Coimbra. In 2005 she got her M.Sc. degree in Electrical Engineering at the Faculty of Engineering of the University of Porto. She is currently a Ph.D. student in Power Systems, also at Faculty of Engineering of the University of Porto. In March 1998 she joined the Department of Electrical Engineering of the School of Technology and Management, Polytechnic Institute of Leiria (Portugal), as an assistant lecturer. Her research interests are in power systems analysis and power system state estimation.

**Fernando Pires Maciel BARBOSA** (M1976, SM1982) was born in Oporto. He graduated from the University of Oporto, in Electrical Engineering, in 1971. In the same year, he joined the staff of the Faculty of Electrical Engineering of the University of Oporto (FEUP), as assistant lecturer. In October 1976

he joined the Department of Electrical Engineering and Electronics at UMIST (Manchester). In 1977 he completed his M.Sc. degree and in 1979 his Ph.D. in Power System Analysis. Presently, he is Full Professor at FEUP in the area of Power Systems. His main research interest includes electric power system reliability, power system stability, power system analysis and related software. He has published several research papers in national and international conferences and journals.

**Jose Antonio Beleza CARVALHO** was born in Oporto, Portugal, in 1959. He received the B.S. degree in Electrical Engineering from the Superior Institute of Engineering of Oporto in 1991, the M.Sc. degree in 1994 and the Ph.D. from the Faculty of Engineering of Oporto University in 1999. He is presently Professor, Coordinator of the Department of Electrical Engineering in Superior Institute of Engineering of Oporto. His research interests are in Power Systems State Estimation, Electrical Machines and Renewable Energies.